

Distribution Code Review Panel

Meeting 66 – Thursday 26 October 2017

Paper by Code Administrator

Phase 1 - DNO progress reporting on changes to RoCoF settings on sites with Power Stations > 5MW

This short report highlights the DNOs 2017 progress as of 20 October 2017 with regards to the required changes to the RoCoF settings on sites with Power Stations > 5MW.

>5MW Power Stations – All Connections

	Total MW	MW of changed settings	MW not applicable	MW WiP
ENW	486.31 (507.1)	272.56 (106.0)	213.75 (153.8)	0
NPg	2460.4 (2469.4)	387.0 (371.2)	2073.4 (1978.9)	0
SPEN	1903.18 (1903.18)	1313.15 (1296.15)	513.03 (513.03)	35.0 (52.0)
SSEPD	2143.99 (2134.3)	1001.35 (338.7)	1142.64 (816.0)	0
UKPN	1482.02 (1482.02)	853.26 (829.46)	628.81 (628.81)	0
WPD	2431.87 (2582.0)	1141.54 (635.0)	1290.33 (1166.7)	0
31/08/17 (Jul 2017)	10907.77 (10916.77)	4968.86 (4951.86)	5861.96 (5767.36)	35.0 (52.0)

Notes that accompanied the DNO submissions.

SPEN

SPD - Complete

SPM - One site completed as planned during September, leaving 1 unit (35MW) remaining. Customer currently assessing offer for network solution.